



Nancy Lacko <nlacko@townoflitchfield.org>

lower level seating - jailhouse patio

Sam Kinkade <firemarshal@townoflitchfield.org>
To: Zoning Admin <Zoningadmin@townoflitchfield.org>
Cc: Nancy Lacko <NLacko@townoflitchfield.org>

Fri, Mar 26, 2021 at 2:14 PM

Dennis,

The lower exterior level as shown on the submitted plan dated 3/11/21 for 7 North Street serves as the exit discharge for Units #1, 2 and 3. Exit discharge is the portion of the means of egress between the termination of an exit (the outside door) and the public way (street, alley or other similar parcel of land open to the outside appropriated to the public having a clear width of no less than 10 feet). The plan shows tables on both sides of the exterior walkway. The dimension of the tables shown is 24" x 24" and the exterior walkway has a width of 96" allowing for 48" for the exit discharge. Give the occupant load of Units #1, 2 and 3 I see no issues with the proposal.

Samuel Kinkade
Fire Marshal
Town of Litchfield

Phone: (860) 567-7568
Fax: (860) 567-7573

[Quoted text hidden]