



Zoning Admin <zoningadmin@townoflitchfield.org>

FW: 19 Little Pitch Road Subdivision

1 message

Scott Lukowski <salukowski@dymarinc.com>

Mon, May 17, 2021 at 8:05 PM

To: "zoningadmin@townoflitchfield.org" <zoningadmin@townoflitchfield.org>

Cc: Greg <greenandsonslc@yahoo.com>, Mark Lancor <melancor@dymarinc.com>

Dennis,

Please see below for the email I received from Aquarion with regards to the existing main on Little Pitch Rd.

Scott A. Lukowski, P.E.

Senior Project Engineer

Dymar

800 Main Street South

Suite 132

Southbury, CT 06488

Office: 203-267-1046

Fax: 203-267-1547

From: Carlos Vizcarrondo [mailto:CVizcarrondo@aquarionwater.com]

Sent: Monday, May 17, 2021 2:29 PM

To: Scott Lukowski <salukowski@dymarinc.com>

Cc: Mark Lancor <melancor@dymarinc.com>

Subject: RE: 19 Little Pitch Road Subdivision

Hi Scott,

The main located at Little Pitch Rd Litchfield is an 8" dip, the pressure may vary but based on the water level and ground elevation you may see pressure reading in the 135psi.

I hope this helps.

Carlos J Vizcarrondo

5/19/2021

townoflitchfield.org Mail - FW: 19 Little Pitch Road Subdivision

Utility Systems Coordinator

Aquarion Water Company of CT

Tel. 203-337-5950

Off. Fax. 203-337-5839

Alt. Fax. 203-330-4647

e-mail:cvizcarrondo@aquarionwater.com

From: Scott Lukowski [mailto:salukowski@dymarinc.com]

Sent: Monday, May 17, 2021 12:42 PM

To: Carlos Vizcarrondo

Cc: Mark Lancor

Subject: 19 Little Pitch Road Subdivision

Aquarion IT Notice - EXTERNAL EMAIL: Do not reply, click on links or open attachments unless you trust the sender AND know the content is safe. Report suspicious emails by forwarding to the IT help desk

Carlos,

How are you? I have another request for a reportedly Aquarion water line in Litchfield (see subject line). The local Fire Marshal is looking for a new hydrant and we need to know the size, water pressure and approximate location of the main. The nearest hydrant is 1800 feet from the site at the intersection of South Plains Road and Camp Dutton Road. We have a P&Z hearing tonight and I just got the fire marshal's comments but we would like to provide, at a minimum, a verbal response.

Thank you,

Scott A. Lukowski, P.E.

Senior Project Engineer

Dymar

800 Main Street South

Suite 132

Southbury, CT 06488

Office: 203-267-1046

Fax: 203-267-1547

This email has been scanned by the Symantec Email Security.cloud service.
